

**HEAD OFFICE**  
**Uttarakhand Environment Protection and Pollution Control Board**  
**29/20, Nemi Road, Dalanwala, Dehra Dun (Uttarakhand)**

Phone : 0135-2658086, Fax : 2718092, Web : www.ueppcb.uk.gov.in, E-mail : msukpcb@yahoo.com

UEPPCB/HO/Con-K-60/2015

1204

Date: 3/11/2015

**REGD. POST**

To,  
M/s Katyayini Paper Mills Pvt. Ltd,  
Near Sodhi Farm, Vill-Kuddiyawala,  
Jaspur Road, Kashipur,  
Distt- U.S.Nagar.

Consolidated Consent to Operate and Authorisation hereinafter referred to as the CCA (Consolidated Consent & authorization) (Expand) under Section-25 of the "Water (Prevention & Control of Pollution) Act, 1974" and under Section-21 of the "Air (Prevention & Control of Pollution) Act, 1981" and Authorization under "Rule-5" of the "Hazardous Waste (Management, Handling and Transboundary Movement) Rules, 2008" notified under "Environment (Protection) Act, 1986" as applicable (to be referred hereinafter as Water Act, Air Act and HW Rules respectively).

PCB ID - 13764

Inward ID - 58913

CCA (Renewal)

Consent No. 35278/S25

Date :- 01.04.2015

CCA is hereby granted to M/s Katyayini Paper Mills Pvt. Ltd located at Vill-Kuddiyawala, Jaspur Road, Kashipur, Distt- U.S.Nagar subject to the provisions of the Water Act, Air Act and HW Rules and the orders that may be made further and subject to following terms and conditions :-

1. This CCA is granted for a period from 01.04.2015 to 31.03.2016 and valid for manufacturing of following products with Capital Investment/Net Assets Values ₹ 26.51Cr :-

S. No.	Last CCA or CTE		Present CCA (Renewal)	
	Product	Quantity (Per Month)	Product	Quantity (Per month)
1	Writing & Printing Paper	1800 MT	Writing & Printing Paper	1800MT

2. Specific Conditions under Water Act :-

- (i) The daily quantity of effluent discharge (KLD) :-

	Last CCA or CTE		Present CCA (Renewal)	
	Trade Effluent	1800	Trade Effluent	1800
Sewage	Nil		Sewage	Nil

- (ii) **Trade Effluent Treatment and Disposal:** The applicant shall operate **Effluent Treatment Plant** consisting of **primary, secondary and tertiary** treatment as is required with reference to influent quantity and quality.

*In case of stoppage of functioning of ETP, production has to be stopped immediately and this Board has to be intimated by fax/phone/email with a report in this regard to be dispatched immediately.*

- (iii) The treated effluent shall be recycled to the maximum extent and remaining treated effluent shall be sent to CETP/Reuse in gardening and the same has to be maintained continuously so as to achieve the quality of the treated effluent to the following general and specific standards as prescribed under **Environment (Protection) Rules, 1986** and applicable to the unit from time-to-time :-

