

EFFLUENT DISCHARGED STANDARDS FOR SEWAGE TREATMENT PLANT

S.NO.	Parameters	Parameters Limit (Standards for New STPs Design after notification date)
1.	pH	6.5-9.0
2.	BOD (mg/L)	Not more than 10
3.	COD (mg/L)	Not more than 50
4.	TSS (mg/L)	Not more than 20
5.	NH-4 (mg/L)	Not more than 5
6.	N-Total (mg/L)	Not more than 10
7.	Fecal Coliform (MPN/100ml)	Less than 100

Note:

(i) These standards will be applicable for discharge in water resources as well as for land disposal. The standards for Fecal Coliform may not be applied for use of treated sewage in industrial purposes.

(ii) * Achievement of Standards for existing STPs within 02 years from the date of notification.