

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Sampling Point							
		Inlet of STP			Outlet of STP			Fecal Coliform	Sampling Date
		pH	BOD	TSS	pH	BOD	TSS		
1	0.26 MLD STP at Badrinath (Banni Gaon), Distt-Chamoli	Sample not taken due to off Season							
2	0.010 MLD STP at Badrinath (Near Temple), Distt-Chamoli								
3	1.0 MLD STP at Badrinath (Near suspension Bridge), Distt-Chamoli								
4	1.080 MLD STP at Joshimath (Pokhri), Distt-Chamoli	6.9	130	142	7.2	8	10	48	09-12-2020
5	0.760 MLD STP at Gopeshwar (Chamoli Ghat), Distt-Chamoli	6.9	125	140	7.4	9.2	14	58	10-12-2020
6	0.050 MLD STP at Gopeshwar (Near old Suspension Bridge), Chamoli	6.8	130	128	7.1	8	12	70	10-12-2020
7	1.190 MLD STP at Gopeshwar (Vivekanand Colony), Distt-Chamoli	6.9	135	146	7.1	10	12	43	09-12-2020
8	1.120 MLD STP at Gopeshwar (Deen Dayal Upadhyay Park), Distt-Chamoli	6.7	140	140	7.1	8	10	32	09-12-2020
9	1.25 MLD STP at Gopeshwar (Pokhari Band), Distt-Chamoli	6.8	125	120	7.2	9.6	10	34	10-12-2020
10	0.050 MLD STP at Nandprayag (Sangam Road), Distt-Chamoli	6.8	120	122	7.3	8.4	10	46	08-12-2020
11	0.100 MLD STP at Nandprayag (Forest office), Distt-Chamoli	6.8	140	148	7	10	12	63	08-12-2020
12	0.050 MLD STP at Karanprayag (Police chowki), Distt-Chamoli	7	135	136	7.3	9.2	10	40	08-12-2020
13	0.100 MLD STP at Karanprayag (Purana pull), Distt-Chamoli	6.7	140	132	7.2	9.6	12	58	08-12-2020
14	0.100 MLD STP at Karanprayag (Ward no. 1&3), Distt-Chamoli	6.8	130	128	7.3	8.4	12	70	08-12-2020
15	0.050 MLD STP at Karanprayag (Subhash Nagar), Distt-Chamoli	6.9	135	142	7.1	9.2	10	63	08-12-2020
16	0.050 MLD STP at Karanprayag (Naya Pull), Distt-Chamoli	6.8	120	146	7.2	9.6	10	58	08-12-2020
17	0.075 MLD MLD STP at Rudraprayag (Near Anoop Negi School)	6.85	115	114	7.2	7.2	8	26	10-12-2020
18	0.100 MLD STP at Rudraprayag (Near Rudra Complex)	6.8	140	136	7.1	10	14	63	10-12-2020
19	0.075 MLD STP at Rudraprayag (Near Bus Stand)	6.7	135	152	7.3	9.2	12	43	10-12-2020
20	0.100 MLD STP at Rudraprayag (Near SBI Maszid)	6.6	140	126	7.2	10	14	58	10-12-2020
21	0.125 MLD STP at Rudraprayag (Near Steel Bridge & Syndicate Bank)	Plant was not in operation due to Electrical Fault							10-12-2020
22	0.050 MLD STP at Beleni Road, Near Steel Bridge, Rudraprayag	6.7	150	110	7.2	9.6	12	38	10-12-2020
23	3.5 MLD STP at Srinagar (Nursary Road)	6.9	160	148	7.2	16	28	140	10-12-2020
24	1.000 MLD STP at Srinagar (Near ITI)	6.8	135	118	6.9	9.2	9	22	10-12-2020
25	0.050 MLD STP at Kirtinagar (BRO Bridge)	7.6	125	120	6.9	8.4	12	46	10-12-2020
26	0.010 MLD STP at Kirtinagar (Near Temple)	6.6	120	116	7.3	9.6	14	43	10-12-2020
27	0.075 MLD STP at Devprayag	6.7	155	124	7.8	14	32	150	10-12-2020
28	0.150 MLD MLD STP at Devprayag	7	160	136	7.2	12	28	170	10-12-2020
29	1.4 MLD STP at Devprayag (Pauri Road)	6.9	165	154	7.2	8	9	70	10-12-2020
30	5 MLD STP at Bhagirathipuram, Tehri	6.96	160	157	7.09	10	22	170	03-12-2020
31	2 MLD STP at Gyansu, Uttarkashi	6.89	165	150	6.71	10	18	140	02-12-2020
32	1 MLD STP at Gangotri, Uttarkashi	Sample not taken due to off Season							
33	3.5 MLD STP at Tapovan Rishikesh	6.7	165	178	7.1	8	12	40	07-12-2020
34	3 MLD STP at Swargashram Rishikesh	6.4	160	146	6.6	7.2	9	22	07-12-2020

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Inlet of STP			Outlet of STP				
35	26 MLD STP at Lakkarghat, Rishikesh	6	170	162	6.6	9.6	10	34	07-12-2020
36	5 MLD STP at Chorpani, Rishikesh	7.31	165	168	8	10	12	46	08-12-2020
37	7.5 MLD STP at Chandreshwar Nagar, Rishikesh	6.56	160	180	6.9	9.2	10	40	08-12-2020
38	20 MLD STP at Motharawala-I, Dehradun	6.45	170	125	6.85	9.2	10	32	02-12-2020
39	20 MLD STP at Motharawala-II, Dehradun	7.09	165	132	7.08	10	12	46	02-12-2020
40	68 MLD STP at Kargi Dehradun	6.92	165	170	6.9	7.6	10	58	02-12-2020
41	0.42 MLD STP at Vijay Colony Dehradun	6.7	175	138	7.18	9.2	18	70	02-12-2020
42	0.72 MLD STP Salawala Dehradun	6.47	170	150	7.15	10	24	170	02-12-2020
43	5.0 MLD STP at Indira Nagar, Dehradun	7.21	165	140	7.35	12	26	150	02-12-2020
44	1.0 MLD STP at Jakhan, Dehradun	7.01	170	165	7.28	14	22	110	02-12-2020
45	27 MLD STP at Jagjeetpur Haridwar	7.4	160	162	7.5	9.2	8	84	08-12-2020
46	18 MLD STP at Jagjeetpur Haridwar	6.9	165	158	7	10	14	58	08-12-2020
47	68 MLD STP at Jagjeetpur Haridwar	7.4	170	165	7.3	9.2	12	40	08-12-2020
48	18 MLD STP at Sarai Haridwar	7.1	160	122	7.3	8	8	26	07-12-2020
49	14 MLD STP at Sarai Haridwar	7.2	165	148	7.1	10	14	39	07-12-2020
50	33 MLD STP at Saliyar, Roorkee, Haridwar	7.2	170	137	7.3	12	18	170	07-12-2020
51	1.3 MLD STP at Landour (S), Mussoorie	7.83	160	168	7.39	10	22	150	03-12-2020
52	3.12 MLD STP at Bhatta fall, Mussoorie	7.3	165	174	7.4	9.6	16	84	03-12-2020
53	0.8 MLD STP at Landour (N), Mussoorie	7.46	155	142	7.1	12	18	170	03-12-2020
54	1.2 MLD STP at Happy Valley, Mussoorie	6.8	165	165	7.38	10	16	150	03-12-2020
55	0.9 MLD STP at Kulri Bazaar, Mussoorie	6.78	160	164	7.39	9.2	15	220	03-12-2020
56	2.0 MLD STP at Almora, Distt-Almora	—	—	—	6.92	48	108	1600	10-12-2020
57	0.45 MLD STP at Hari Nagar, Distt-Nainital	—	—	—	7.68	22	40	280	10-12-2020
58	0.80 MLD STP at Krishnapur, Distt-Nainital	—	—	—	7.71	18	32	210	10-12-2020
59	1.25 MLD STP at Bheemtal, Distt-Nainital	—	—	—	6.15	36	92	350	10-12-2020
60	5.0 MLD STP at Aincholi, Distt-Pithoragarh	—	—	—	7.84	24	46	540	10-12-2020
61	1.25 MLD STP at Nirada, Distt-Pithoragarh	—	—	—	6.14	52	144	>1600	10-12-2020
Sewage Treatment final effluent standards					6.5-9.0	30	<50	<1000	
Note: All values are in mg/l except pH and fecal coliform (MPN Per 100 ml)									