



CENTRAL LABORATORY

Analysis Report of Sewage Treatment Plants (STP's) for the Month of March 2021

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Sampling Point						
		Inlet of STP			Outlet of STP			Fecal Coliform
		pH	BOD	TSS	pH	BOD	TSS	
1	0.26 MLD STP at Badrinath (Banni Gaon), Chamoli	STP's are not monitored because of seasonal closure of Badrinath and Gangotri.						
2	0.010 MLD STP at Badrinath (Near Temple), Chamoli							
3	1 MLD STP at Badrinath (Near suspension Bridge), Chamoli							
4	1 MLD STP at Gangotri, Uttarkashi							
5	1.080 MLD STP at Joshimath (Pokhri)	7.43	125	110	7.85	9.6	10	70
6	0.760 MLD STP at Gopeshwar (Chamoli Ghat)	6.90	140	138	7.60	9.2	9	79
7	0.050 MLD STP at Gopeshwar (Near old Suspension Bridge), Chamoli	6.85	120	112	7.43	8	8	63
8	1.190 MLD STP at Gopeshwar (Vivekanand Colony)	7.50	120	132	7.45	8.8	9	70
9	1.120 MLD STP at Gopeshwar (DeenDayal Upadhyay Park)	6.94	110	130	7.60	10	9	58
10	1.25 MLD STP at Gopeshwar (Pokhari Band)	6.65	105	116	7.70	8	8	43
11	0.050 MLD STP at Nandprayag (Sangam Road)	8.04	110	134	7.43	9.2	9	40
12	0.100 MLD STP at Nandprayag (Forest office)	8.39	135	144	8.16	9.6	10	84
13	0.050 MLD STP at Karanprayag (Police chowki)	7.50	110	136	8.10	9.6	10	58
14	0.100 MLD STP at Karanprayag (Purana Pull)	6.75	145	156	7.26	8.8	8	63
15	0.100 MLD STP at Karanprayag (Ward no. 1&3)	8.04	120	128	8.19	8	9	70
16	0.050 MLD STP at Karanprayag (Subhash Nagar)	6.89	110	118	6.77	10	9	94
17	0.050 MLD STP at Karanprayag (Naya Pull)	6.80	105	120	7.66	9.6	9	58
18	0.075 MLD MLD STP at Rudraprayag (Near Anoop Negi School)	6.86	100	110	7.41	7.6	9	38
19	0.100 MLD STP at Rudraprayag (Near Rudra Complex)	6.74	120	134	8.15	9.2	9	63
20	0.075 MLD STP at Rudraprayag (Near Bus Stand)	6.70	110	128	7.32	10	10	79
21	0.100 MLD STP at Rudraprayag (Near SBI Masjid)	6.69	125	132	7.71	9.6	10	84
22	0.125 MLD STP at Rudraprayag (Near Steel	7.68	115	126	7.21	8.8	9	58



CENTRAL LABORATORY

	Bridge & Syndicate Bank)							
23	50 KLD STP at Beleni Road, Near Steel Bridge, Rudraprayag	7.97	130	116	7.51	10	9	70
24	3.5 MLD STP at Srinagar (Nursary Road)	7.38	150	156	7.66	12	14	130
25	1.000 MLD STP at Srinagar (Near ITI)	7.85	120	108	7.40	9.2	9	40
26	75 KLD STP Near Junior High School, Srikot, Srinagar	7.24	100	125	7.68	9.6	9	39
27	50 KLD STP Near Tauliya Nala, Srikot, Srinagar.	7.66	125	140	7.30	10	10	58
28	0.050 MLD STP at Kirtinagar (BRO Bridge)	6.91	115	135	7.58	9.2	9	47
29	0.010 MLD STP at Kirtinagar (Near Temple)	6.90	120	138	7.22	10	12	79
30	0.075 MLD STP at Devprayag	7.85	145	154	7.36	20	32	110
31	0.150 MLD MLD STP at Devprayag	7.21	150	162	7.81	18	34	94
32	1.4 MLD STP at Devprayag (Pauri Road)	6.76	160	148	7.22	9.2	9	84
33	5 MLD STP at Bhagirathipuram, Tehri	7.02	170	158	7.40	9.6	10	79
34	2 MLD STP at Gyansu, Uttarkashi	7.51	160	162	7.87	9.2	10	94
35	3.5 MLD STP at Tapovan Rishikesh	6.84	160	144	7.54	8.8	8	46
36	3 MLD STP at Swargashram Rishikesh	6.72	155	138	7.62	8.0	9	40
37	26 MLD STP at Lakkarghat, Rishikesh	6.38	150	144	7.60	9.2	10	38
38	5 MLD STP at Chorpani, Rishikesh	6.78	160	158	7.82	10	9	70
39	7.5 MLD STP at Chandreshwar Nagar, Rishikesh	6.83	165	150	7.75	9.6	10	40
40	20 MLD STP at Motharawala-I, Dehradun	6.86	165	158	7.94	9.6	9	63
41	20 MLD STP at Motharawala-II, Dehradun	6.80	160	164	7.35	10	10	79
42	68 MLD STP at Kargi Dehradun	6.78	165	152	7.82	9.2	9	70
43	0.42 MLD STP at Vijay Colony Dehradun	6.67	155	140	7.80	9.6	10	94
44	0.72 MLD STP Salawala Dehradun	6.56	160	144	7.92	9.2	9	84
45	5.0 MLD STP at Indira Nagar, Dehradun	6.90	160	162	7.89	9.2	9	94
46	1.0 MLD STP at Jakhan, Dehradun	6.85	125	136	7.11	8.8	9	70
47	27 MLD STP at Jagjeetpur Haridwar	7.60	165	148	7.80	9.6	10	94
48	18 MLD STP at Jagjeetpur Haridwar	7.66	160	156	7.93	9.2	9	70
49	68 MLD STP at Jagjeetpur Haridwar	7.65	165	172	7.70	8.8	8	63
50	18 MLD STP at Sarai Haridwar	7.82	155	140	7.95	8.4	9	46
51	14 MLD STP at Sarai Haridwar	7.70	160	145	8.27	9.2	10	38
52	33 MLD STP at Saliyar, Roorkee, Haridwar	7.68	165	158	7.45	9.6	10	94
53	1.3 MLD STP at Landour (S), Mussoorie	7.56	130	124	8.06	8.8	9	70
54	3.12 MLD STP at Bhatta fall, Mussoorie	7.24	135	140	7.63	9.2	8	79
55	0.8 MLD STP at Landour (N), Mussoorie	6.89	110	126	6.62	8.4	9	94
56	1.2 MLD STP at Happy Valley, Mussoorie	7.27	140	138	8.08	10	9	110
57	0.9 MLD STP at Kulri Bazaar, Mussoorie	6.83	125	137	7.56	14	18	130
58	2.0 MLD STP at Almora, Distt-Almora	—	—	—	7.32	26	58	—

UTTARAKHAND POLLUTION CONTROL BOARD
GauradeviParayavaran Bhawan
46-B, SIDCUL, IT Park, Sahashtradhara Road
DEHRADUN (Uttarakhand)



उत्तराखण्डप्रदूषणनियंत्रण बोर्ड
गौरादेवीपर्यावरणभवन
46-बी, सिडकुल,आई.टी. पार्क, सहस्रधारारोड़,
देहरादून(उत्तराखण्ड)

CENTRAL LABORATORY

59	0.45 MLD STP at Hari Nagar, Distt-Nainital	—	—	—	7.64	22	36	—
60	0.80 MLD STP at Krishnapur, Distt-Nainital	—	—	—	7.25	18	42	—
61	1.25 MLD STP at Bheemtal, Distt-Nainital	—	—	—	6.97	29	64	—
62	5.0 MLD STP at Aincholi, Distt-Pithoragarh	—	—	—	7.84	18	44	—
63	1.25 MLD STP at Nirada, Distt-Pithoragarh	—	—	—	6.91	16	52	—
Sewage Treatment final effluent standards					6.5 -9.0	<30	<50	<1000
Note: All values are in mg/l except pH and fecal coliform (MPN Per 100 ml)								

(S.K.Dimri)
Asst. Scientific Officer

(S.S. Pal)
Chief Environment Officer