



CENTRAL LABORATORY

Analysis Report of Sewage Treatment Plants (STP's) for the Month of February2021

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Sampling Point						
		Inlet of STP			Outlet of STP			Fecal Coliform
		pH	BOD	TSS	pH	BOD	TSS	
1	0.26 MLD STP at Badrinath (Banni Gaon),Chamoli	STP's are not monitored because of seasonal closure of Badrinath and Gangotri.						
2	0.010 MLD STP at Badrinath (Near Temple), Chamoli							
3	1 MLD STP at Badrinath (Near suspension Bridge), Chamoli							
4	1 MLD STP at Gangotri, Uttarkashi							
5	1.080 MLD STP at Joshimath (Pokhri)	6.95	120	118	8.47	9.2	8	63
6	0.760 MLD STP at Gopeshwar (Chamoli Ghat)	6.67	130	122	7.15	10	10	70
7	0.050 MLD STP at Gopeshwar (Near old Suspension Bridge),Chamoli	6.72	135	128	6.91	8.8	9	94
8	1.190 MLD STP at Gopeshwar (Vivekanand Colony)	6.81	110	108	7.22	8.4	7	58
9	1.120 MLD STP at Gopeshwar (DeenDayal Upadhyay Park)	6.02	115	124	6.87	9.2	9	48
10	1.25 MLD STP at Gopeshwar (Pokhari Band)	6.56	125	132	7.04	7.6	8	40
11	0.050 MLD STP at Nandprayag (Sangam Road)	6.85	100	126	7.51	8.4	10	32
12	0.100 MLD STP at Nandprayag (Forest office)	7.43	140	138	7.08	10	9	70
13	0.050 MLD STP at Karanprayag (Police chowki)	7.70	120	122	7.45	9.2	10	43
14	0.100 MLD STP at Karanprayag (Purana Pull)	6.69	140	135	7.31	8.4	9	58
15	0.100 MLD STP at Karanprayag (Ward no. 1&3)	7.25	125	110	7.29	7.6	10	94
16	0.050 MLD STP at Karanprayag (Subhash Nagar)	6.77	120	136	7.45	9.2	9	84
17	0.050 MLD STP at Karanprayag (Naya Pull)	6.78	100	112	7.38	10	8	63
18	0.075 MLD MLD STP at Rudraprayag (Near Anoop Negi School)	7.0	90	102	7.21	7.2	8	26
19	0.100 MLD STP at Rudraprayag (Near Rudra Complex)	6.58	115	125	6.90	8.8	10	58
20	0.075 MLD STP at Rudraprayag (Near Bus Stand)	6.95	120	140	7.63	9.6	10	70
21	0.100 MLD STP at Rudraprayag (Near SBI Maszid)	6.64	130	128	7.64	10	12	79
22	0.125 MLD STP at Rudraprayag (Near Steel	6.86	125	134	7.44	9.2	10	46



CENTRAL LABORATORY

	Bridge & Syndicate Bank)							
23	50 KLD STP at Beleni Road, Near Steel Bridge, Rudraprayag	6.62	145	122	6.84	9.6	9	48
24	3.5 MLD STP at Srinagar (Nursary Road)	6.82	160	148	7.15	16	22	140
25	1.000 MLD STP at Srinagar (Near ITI)	6.78	125	110	7.09	8.8	8	32
26	75 KLD STP Near Junior High School, Srikot, Srinagar	6.76	105	118	7.58	10	10	47
27	50 KLD STP Near Tauliya Nala, Srikot, Srinagar.	6.81	120	136	6.98	9.6	12	63
28	0.050 MLD STP at Kirtinagar (BRO Bridge)	6.84	110	118	7.48	8.4	8	40
29	0.010 MLD STP at Kirtinagar (Near Temple)	6.54	120	132	6.94	9.6	10	70
30	0.075 MLD STP at Devprayag	6.67	150	142	7.20	18	28	84
31	0.150 MLD MLD STP at Devprayag	6.93	155	148	7.05	16	26	70
32	1.4 MLD STP at Devprayag (Pauri Road)	6.86	165	170	6.92	9.6	10	79
33	5 MLD STP at Bhagirathipuram, Tehri	7.12	160	152	7.01	10	10	84
34	2 MLD STP at Gyansu, Uttarkashi	6.28	165	158	7.32	9.6	14	120
35	3.5 MLD STP at Tapovan Rishikesh	6.48	165	172	7.50	9.2	9	40
36	3 MLD STP at Swargashram Rishikesh	6.55	150	164	7.69	8.4	9	32
37	26 MLD STP at Lakkarghat, Rishikesh	6.23	160	156	7.65	8.8	9	43
38	5 MLD STP at Chorpani, Rishikesh	6.87	165	174	7.91	9.6	10	94
39	7.5 MLD STP at Chandreshwar Nagar, Rishikesh	6.38	155	165	7.81	10	10	34
40	20 MLD STP at Motharawala-I, Dehradun	7.60	170	162	7.47	9.2	8	70
41	20 MLD STP at Motharawala-II, Dehradun	7.38	165	172	7.63	9.6	9	84
42	68 MLD STP at Kargi Dehradun	7.40	170	158	7.34	8.8	10	94
43	0.42 MLD STP at Vijay Colony Dehradun	6.61	160	138	7.10	9.2	12	84
44	0.72 MLD STP Salawala Dehradun	7.34	165	142	7.64	8.4	10	70
45	5.0 MLD STP at Indira Nagar, Dehradun	7.20	165	170	8.47	9.6	10	110
46	1.0 MLD STP at Jakhan, Dehradun	7.11	120	130	7.46	9.2	10	120
47	27 MLD STP at Jagjeetpur Haridwar	7.05	170	152	7.65	9.2	8	84
48	18 MLD STP at Jagjeetpur Haridwar	7.26	165	148	7.68	8.8	10	63
49	68 MLD STP at Jagjeetpur Haridwar	7.04	170	156	7.41	9.2	9	58
50	18 MLD STP at Sarai Haridwar	6.80	160	142	7.35	8	8	40
51	14 MLD STP at Sarai Haridwar	7.25	165	148	7.40	9.6	9	43
52	33 MLD STP at Saliyar, Roorkee, Haridwar	7.41	170	147	7.84	9.2	12	120
53	1.3 MLD STP at Landour (S), Mussoorie	6.70	135	128	7.83	9.2	10	94
54	3.12 MLD STP at Bhatta fall, Mussoorie	6.36	140	154	7.75	9.6	9	84
55	0.8 MLD STP at Landour (N), Mussoorie	6.85	120	112	7.74	9.2	10	110
56	1.2 MLD STP at Happy Valley, Mussoorie	6.47	150	134	7.64	8.8	9	130
57	0.9 MLD STP at Kulri Bazaar, Mussoorie	6.45	130	122	7.10	16	10	150
58	2.0 MLD STP at Almora, Distt-Almora	—	—	—	7.81	22	64	—

UTTARAKHAND POLLUTION CONTROL BOARD
GauradeviParayavaran Bhawan
46-B, SIDCUL, IT Park, Sahashtradhara Road
DEHRADUN (Uttarakhand)



उत्तराखण्डप्रदूषणनियंत्रण बोर्ड
गौरादेवीपर्यावरणभवन
46-बी, सिडकुल,आई.टी. पार्क, सहस्त्रधारारोड़,
देहरादून(उत्तराखण्ड)

CENTRAL LABORATORY

59	0.45 MLD STP at Hari Nagar, Distt-Nainital	—	—	—	7.18	12	38	—
60	0.80 MLD STP at Krishnapur, Distt-Nainital	—	—	—	6.93	16	32	—
61	1.25 MLD STP at Bheemtal, Distt-Nainital	—	—	—	7.24	27	66	—
62	5.0 MLD STP at Aincholi, Distt-Pithoragarh	—	—	—	7.35	18	52	—
63	1.25 MLD STP at Nirada, Distt-Pithoragarh	—	—	—	7.66	24	44	—
Sewage Treatment final effluent standards					6.5 -9.0	<30	<50	<1000
Note: All values are in mg/l except pH and fecal coliform (MPN Per 100 ml)								

(S.K.Dimri)
Asst. Scientific Officer

(S.S. Pal)
Chief Environment Officer