



CENTRAL LABORATORY

Analysis Report of Sewage Treatment Plants (STP's) for the Month of August2021

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Sampling Point						
		Inlet of STP			OutletofSTP			
		pH	BOD	TSS	pH	BOD	TSS	Fecal Coliform
1	1.080 MLD STP at Joshimath (Pokhri)	7.2	120	112	8.0	10	9	84
2	0.760 MLD STP at Gopeshwar (Chamoli Ghat)	6.66	135	130	6.85	9.6	10	110
3	0.050 MLD STP at Gopeshwar (Near old Suspension Bridge),Chamoli	6.58	130	118	6.54	9.2	8	70
4	1.190 MLD STP at Gopeshwar (Vivekanand Colony)	7.53	110	126	8.50	8	10	79
5	1.120 MLD STP at Gopeshwar (DeenDayal Upadhyay Park)	7.07	115	124	6.80	9.6	12	63
6	1.25 MLD STP at Gopeshwar (Pokhari Band)	8.0	110	132	8.33	8.8	9	58
7	0.050 MLD STP at Nandprayag (Sangam Road)	6.35	120	108	6.76	9.6	8	70
8	0.100 MLD STP at Nandprayag (Forest office)	6.81	160	155	STP was not operated properly. Over flow directly discharge into Nandakini River.			
9	0.050 MLD STP at Karanprayag (Police chowki)	6.74	120	140	7.30	10	14	79
10	0.100 MLD STP at Karanprayag (Purana Pull)	6.80	155	162	STP's werenot in operation. effluent directly discharge into Pindar River.			
11	0.100 MLD STP at Karanprayag (Ward no. 1&3)	7.28	165	160				
12	0.050 MLD STP at Karanprayag (Subhash Nagar)	6.46	120	128	7.29	10	10	110
13	0.050 MLD STP at Karanprayag (Naya Pull)	6.70	110	134	7.38	9.2	8	70
14	0.075 MLD MLD STP at Rudraprayag (Near Anoop Negi School)	7.15	110	104	6.81	8	8	40
15	0.100 MLD STP at Rudraprayag (Near Rudra Complex)	7.10	130	117	7.12	10	9	70
16	0.075 MLD STP at Rudraprayag (Near Bus Stand)	6.96	115	126	6.85	9.6	9	84
17	0.100 MLD STP at Rudraprayag (Near SBI Maszid)	6.95	130	144	6.80	10	14	110
18	0.125 MLD STP at Rudraprayag (Near Steel Bridge & Syndicate Bank)	6.73	120	116	7.08	9.2	10	70
19	0.050 MLD STP at Beleni Road, Near Steel Bridge, Rudraprayag	7.02	120	128	6.86	10	10	84
20	3.5 MLD STP at Srinagar (Nursary Road)	6.98	160	162	7.76	22	42	350



CENTRAL LABORATORY

21	1.000 MLD STP at Srinagar (Near ITI)	7.15	130	112	8.44	9.2	9	280
22	0.075 MLD STP Near Junior High School, Srikot, Srinagar	6.79	170	166	STP was not operated properly. Over flow directly discharge into Alaknanda River.			
23	0.050 MLD STP Near Tauliya Nala, Srikot, Srinagar.	7.32	120	136	7.40	12	32	94
24	0.050 MLD STP at Kirtinagar (BRO Bridge)	6.75	115	110	7.08	9.2	10	46
25	0.010 MLD STP at Kirtinagar (Near Temple)	6.83	125	122	7.10	9.6	9	110
26	0.075 MLD STP at Devprayag	Plant was not in operation because of sewage line breakage due to cloud burst.						
27	0.150 MLD MLD STP at Devprayag	6.74	155	162	7.52	20	36	430
28	1.4 MLD STP at Devprayag (Pauri Road)	7.0	165	144	7.2	10	8	130
29	5 MLD STP at Bhagirathipuram, Tehri	7.02	160	170	6.56	9.6	10	170
30	2 MLD STP at Gyansu, Uttarkashi	7.35	160	158	7.65	9.2	9	84
31	3.5 MLD STP at Tapovan Rishikesh	7.35	170	145	7.81	9.6	10	33
32	3 MLD STP at Swargashram Rishikesh	7.12	155	136	7.45	9.2	9	27
33	26 MLD STP at Lakkarghat, Rishikesh	6.48	160	144	7.75	9.6	9	40
34	5 MLD STP at Chorpani, Rishikesh	7.33	165	150	7.61	10	10	220
35	7.5 MLD STP at Chandreshwar Nagar, Rishikesh	7.40	170	152	8.15	9.6	12	34
36	20 MLD STP at Motharawala-I, Dehradun	7.2	165	157	7.6	9.2	10	70
37	20 MLD STP at Motharawala-II, Dehradun	6.7	160	163	7.1	12	18	170
38	68 MLD STP at Kargi Dehradun	7.2	160	152	7.5	9.2	9	63
39	0.42 MLD STP at Vijay Colony Dehradun	7.3	155	140	7.5	10	12	350
40	0.72 MLD STP Salawala Dehradun	7.3	160	142	7.6	9.2	10	70
41	5.0 MLD STP at Indira Nagar, Dehradun	7.3	160	162	7.6	10	9	84
42	1.0 MLD STP at Jakhan, Dehradun	7.2	125	132	7.7	9.6	12	110
43	27 MLD STP at Jagjeetpur Haridwar	7.26	165	148	7.79	9.2	10	120
44	18 MLD STP at Jagjeetpur Haridwar	7.44	160	152	7.46	9.6	9	84
45	68 MLD STP at Jagjeetpur Haridwar	7.35	165	170	7.39	9.2	9	63
46	18 MLD STP at Sarai Haridwar	7.37	160	148	7.89	8.8	8	32
47	14 MLD STP at Sarai Haridwar	7.53	170	145	7.70	9.6	10	79
48	33 MLD STP at Saliyar, Roorkee, Haridwar	7.21	165	160	7.76	10	9	94
49	1.3 MLD STP at Landour (S), Mussoorie	7.18	125	115	7.6	8.8	8	63
50	3.12 MLD STP at Bhatta fall, Mussoorie	7.0	135	140	7.7	9.2	10	79
51	0.8 MLD STP at Landour (N), Mussoorie	7.2	120	138	7.1	12	14	70
52	1.2 MLD STP at Happy Valley, Mussoorie	7.4	140	136	8.0	9.6	12	84
53	0.9 MLD STP at Kulri Bazaar, Mussoorie	7.3	125	130	7.5	10	16	150
54	2.0 MLD STP at Almora, Distt-Almora	—	—	—	7.15	18	44	240
55	0.45 MLD STP at Hari Nagar, Distt-Nainital	—	—	—	7.29	26	56	540
56	0.80 MLD STP at Krishnapur, Distt-Nainital	—	—	—	7.51	16	34	350
57	1.25 MLD STP at Bheental, Distt-Nainital	—	—	—	6.94	20	72	350

UTTARAKHAND POLLUTION CONTROL BOARD
GauradeviParayavaran Bhawan
46-B, SIDCUL, IT Park, Sahashtradhara Road
DEHRADUN (Uttarakhand)



उत्तराखण्डप्रदूषणनियंत्रण बोर्ड
गौरादेवीपर्यावरणभवन
46-बी, सिडकुल,आई.टी. पार्क, सहस्त्रधारा रोड़,
देहरादून(उत्तराखण्ड)

CENTRAL LABORATORY

58	5.0 MLD STP at Aincholi, Distt-Pithoragarh	—	—	—	7.53	12	28	70
59	1.25 MLD STP at Nirada, Distt-Pithoragarh	—	—	—	7.75	22	36	280
60	1.5 MLD STP at Puchdi, Ramnagar, Nainital	—	—	—	7.93	24	54	920
61	7.0 MLD STPHaldwani By Pass Bridge,Ramnagar Nainital.	—	—	—	8.14	28	62	920
Sewage Treatment final effluent standards					6.5 -9.0	<30	<100	<1000
Note: All values are in mg/l except pH and fecal coliform (MPN Per 100 ml)								

* The Monitoring of 04 STP's (Badrinath-03No. and Gangotri-01No.) not performed as "Char-Dham Yatra" is restricted.