

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Sampling Point							
		Inlet of STP			Outlet of STP			Fecal Coliform	Sampling Date
		pH	BOD	TSS	pH	BOD	TSS		
1	0.26 MLD STP at Badrinath (Banni Gaon), Distt-Chamoli	7.04	140	148	6.93	8	22	110	17-09-2020
2	0.010 MLD STP at Badrinath (Near Temple), Distt-Chamoli	6.72	135	154	6.78	10	18	80	17-09-2020
3	1.0 MLD STP at Badrinath (Near suspension Bridge), Distt-Chamoli	Not in Operation							17-09-2020
4	1.080 MLD STP at Joshimath (Pokhri), Distt-Chamoli	6.87	140	132	7.55	9.2	16	220	17-09-2020
5	0.760 MLD STP at Gopeshwar (Chamoli Ghat), Distt-Chamoli	6.80	130	138	7.66	10	18	70	17-09-2020
6	0.050 MLD STP at Gopeshwar (Near old Suspension Bridge), Chamoli	6.74	135	140	6.89	8	18	90	17-09-2020
7	1.190 MLD STP at Gopeshwar (Vivekanand Colony), Distt-Chamoli	Plant was under Service Maintenance							17-09-2020
8	1.120 MLD STP at Gopeshwar (Deen Dayal Upadhyay Park), Distt-Chamoli	6.75	140	125	7.6	10	24	80	17-09-2020
9	1.25 MLD STP at Gopeshwar (Pokhari Band), Distt-Chamoli	6.85	145	128	7.68	9.6	22	110	17-09-2020
10	0.050 MLD STP at Nandprayag (Sangam Road), Distt-Chamoli	7.3	130	146	7.18	8	18	80	17-09-2020
11	0.100 MLD STP at Nandprayag (Forest office), Distt-Chamoli	6.92	145	137	6.94	9.2	20	170	17-09-2020
12	0.050 MLD STP at Karanprayag (Police chowki), Distt-Chamoli	6.82	140	136	7.3	8.8	18	70	17-09-2020
13	0.100 MLD STP at Karanprayag (Purana pull), Distt-Chamoli	6.74	145	138	7.34	10	29	140	17-09-2020
14	0.100 MLD STP at Karanprayag (Ward no. 1&3), Distt-Chamoli	6.82	150	154	7.55	9.2	18	110	17-09-2020
15	0.050 MLD STP at Karanprayag (Subhash Nagar), Distt-Chamoli	6.74	140	130	7.04	8.8	20	90	17-09-2020
16	0.050 MLD STP at Karanprayag (Naya Pull), Distt-Chamoli	6.82	145	140	7.99	10	22	80	17-09-2020
17	0.075 MLD MLD STP at Rudraprayag (Near Anoop Negi School)	7.62	130	126	7.35	7.6	17	60	18-09-2020
18	0.100 MLD STP at Rudraprayag (Near Rudra Complex)	6.80	135	142	7.74	10	26	70	18-09-2020
19	0.075 MLD STP at Rudraprayag (Near Bus Stand)	Not in Operation							18-09-2020
20	0.100 MLD STP at Rudraprayag (Near SBI Maszid)	6.78	120	142	6.87	8	10	60	18-09-2020
21	0.125 MLD STP at Rudraprayag (Near Steel Bridge & Syndicate Bank)	7.11	130	134	7.24	8.8	14	50	18-09-2020
22	3.5 MLD STP at Srinagar (Nursary Road)	6.72	170	164	7.21	14	42	350	18-09-2020
23	1.000 MLD STP at Srinagar (Near ITI)	6.61	150	156	8.32	8.4	18	50	18-09-2020

24	0.050 MLD STP at Kirtinagar (BRO Bridge)	6.95	125	142	7.14	9.6	14	60	18-09-2020
25	0.010 MLD STP at Kirtinagar (Near Temple)	6.56	135	140	7.12	10	18	40	18-09-2020
26	0.075 MLD STP at Devprayag	6.74	155	148	8.27	16	32	350	18-09-2020
27	0.150 MLD MLD STP at Devprayag	6.59	150	153	7.38	14	35	280	18-09-2020
28	1.4 MLD STP at Devprayag (Pauri Road)	6.76	165	166	7.47	9.6	10	220	18-09-2020
29	5 MLD STP at Bhagirathipuram, Tehri	6.80	160	168	7.6	14	42	280	21-09-2020
30	2 MLD STP at Gyansu, Uttarkashi	6.92	165	170	7.53	12	38	500	09-09-2020
31	1 MLD STP at Gangotri, Uttarkashi	6.46	165	174	7.43	9.6	16	40	08-09-2020
32	3.5 MLD STP at Tapovan Rishikesh	6.94	160	165	7.68	9.2	14	34	02-09-2020
33	3 MLD STP at Swargashram Rishikesh	6.58	165	162	7.23	8	12	30	02-09-2020
34	26 MLD STP at Lakkarghat, Rishikesh	6.91	165	172	7.32	14	42	280	02-09-2020
35	5 MLD STP at Chorpani, Rishikesh	6.86	165	158	7.13	8.8	22	500	02-09-2020
36	7.5 MLD STP at Chandreshwar Nagar, Rishikesh	6.82	160	155	7.87	12	26	220	02-09-2020
37	20 MLD STP at Motharawala-I, Dehradun	7.03	170	158	7.57	10	24	40	07-09-2020
38	20 MLD STP at Motharawala-II, Dehradun	7.0	165	164	6.82	16	42	90	07-09-2020
39	68 MLD STP at Kargi Dehradun	6.7	170	182	7.7	9.6	12	110	07-09-2020
40	0.42 MLD STP at Vijay Colony Dehradun	7.24	160	148	7.83	18	36	500	07-09-2020
41	0.72 MLD STP Salawala Dehradun	7.27	165	154	7.6	16	32	500	07-09-2020
42	5.0 MLD STP at Indira Nagar, Dehradun	7.66	160	158	7.84	14	30	350	07-09-2020
43	1.0 MLD STP at Jakhan, Dehradun	7.78	170	162	8.27	12	26	280	07-09-2020
44	1.3 MLD STP at Landour (S), Mussoorie	Not in Operation							14-09-2020
45	3.12 MLD STP at Bhatta fall, Mussoorie	7.73	160	138	7.57	14	45	220	14-09-2020
46	0.8 MLD STP at Landour (N), Mussoorie	7.27	170	145	8.48	12	40	350	14-09-2020
47	0.9 MLD STP at Kulri Bazaar, Mussoorie	7.37	165	182	8.24	16	48	500	14-09-2020
48	1.2 MLD STP at Happy Valley, Mussoorie	7.38	170	166	8.14	18	34	280	14-09-2020
49	27 MLD STP at Jagjeetpur Haridwar	7.10	165	162	8.4	9.2	10	70	14-09-2020

50	18 MLD STP at Jagjeetpur Haridwar	7.29	160	174	7.82	10	32	110	14-09-2020
51	68 MLD STP at Jagjeetpur Haridwar	7.22	170	168	7.46	12	28	140	14-09-2020
52	18 MLD STP at Sarai Haridwar	7.39	170	159	7.32	8	10	50	14-09-2020
53	14 MLD STP at Sarai Haridwar	6.97	165	148	8.18	9.2	24	90	14-09-2020
54	33 MLD STP at Saliyar, Roorkee, Haridwar	7.66	160	170	7.56	10	26	280	14-09-2020
55	2.0 MLD STP at Almora, Distt-Almora	—	—	—	8.19	30	76	920	08-09-2020
56	0.45 MLD STP at Hari Nagar, Distt-Nainital	—	—	—	7.63	21	62	350	08-09-2020
57	0.80 MLD STP at Krishnapur, Distt-Nainital	—	—	—	7.35	18	74	280	08-09-2020
58	1.25 MLD STP at Bheemtal, Distt-Nainital	—	—	—	6.88	36	112	430	08-09-2020
59	10 MLD(5MLD×2) Rusi Pond at Rusi, Distt-Nainital				6.21	160	184	>1600	08-09-2020
60	5.0 MLD STP at Aincholi, Distt-Pithoragarh	—	—	—	7.31	29	58	920	08-09-2020
61	1.25 MLD STP at Nirada, Distt-Pithoragarh	—	—	—	7.71	26	44	540	08-09-2020
Sewage Treatment final effluent standards					6.5-9.0	30	<50	<1000	
Note: All values are in mg/l except pH and fecal coliform (MPN Per 100 ml)									