

S.No.	Name of the Sewage Treatment Plant (With Capacity )	Sampling Point							
		Inlet of STP			Outlet of STP			Fecal	Sampling
		pH	BOD	TSS	pH	BOD	TSS		
1	0.26 MLD STP at Badrinath (Banni Gaon), Distt-Chamoli	6.89	150	187	7.39	7.6	14	84	24-10-2020
2	0.010 MLD STP at Badrinath (Near Temple), Distt-Chamoli	6.65	140	166	7.33	9.2	12	70	24-10-2020
3	1.0 MLD STP at Badrinath (Near suspension Bridge), Distt-Chamoli	7.04	145	154	7.41	10	22	63	24-10-2020
4	1.080 MLD STP at Joshimath (Pokhri), Distt-Chamoli	6.62	145	138	7.62	8	18	140	24-10-2020
5	0.760 MLD STP at Gopeshwar (Chamoli Ghat), Distt-Chamoli	7.88	135	142	7.39	7.2	10	58	24-10-2020
6	0.050 MLD STP at Gopeshwar (Near old Suspension Bridge), Chamoli	6.81	140	155	7.25	8.8	12	70	24-10-2020
7	1.190 MLD STP at Gopeshwar (Vivekanand Colony), Distt-Chamoli	6.9	145	158	7.54	10	22	110	24-10-2020
8	1.120 MLD STP at Gopeshwar (Deen Dayal Upadhyay Park ), Distt-Chamoli	6.91	130	142	7.51	6.4	14	58	24-10-2020
9	1.25 MLD STP at Gopeshwar (Pokhari Band), Distt-Chamoli	6.76	140	130	7.55	9.2	16	70	24-10-2020
10	0.050 MLD STP at Nandprayag (Sangam Road), Distt-Chamoli	7.48	135	148	7.87	8	14	46	24-10-2020
11	0.100 MLD STP at Nandprayag (Forest office), Distt-Chamoli	7.54	140	144	7.55	6.4	10	110	24-10-2020
12	0.050 MLD STP at Karanprayag (Police chowki), Distt-Chamoli	6.71	145	156	7.55	9.2	14	79	25-10-2020
13	0.100 MLD STP at Karanprayag (Purana pull ), Distt-Chamoli	7.54	140	142	7.57	9.6	18	94	25-10-2020
14	0.100 MLD STP at Karanprayag (Ward no. 1&3), Distt-Chamoli	6.85	145	156	7.71	10	15	70	25-10-2020
15	0.050 MLD STP at Karanprayag (Subhash Nagar), Distt-Chamoli	7.57	135	147	7.58	10	18	49	25-10-2020
16	0.050 MLD STP at Karanprayag (Naya Pull), Distt-Chamoli	7.42	140	154	7.38	9.2	14	58	25-10-2020
17	0.075 MLD MLD STP at Rudraprayag (Near Anoop Negi School )	7.42	135	128	7.72	7	12	48	25-10-2020
18	0.100 MLD STP at Rudraprayag (Near Rudra Complex)	7.53	140	135	7.68	8	20	46	25-10-2020
19	0.075 MLD STP at Rudraprayag (Near Bus Stand)	Due to NH Project work sewage work disturbed and plant							25-10-2020
20	0.100 MLD STP at Rudraprayag (Near SBI Masjid )	7.4	130	134	7.13	6.6	10	63	25-10-2020
21	0.125 MLD STP at Rudraprayag (Near Steel Bridge & Syndicate Bank )	6.7	135	140	7.91	8	16	40	25-10-2020
22	3.5 MLD STP at Srinagar (Nursary Road)	6.69	160	174	7.21	16	48	240	25-10-2020
23	1.000 MLD STP at Srinagar (Near ITI)	7.7	140	138	8.36	9.6	12	38	25-10-2020
24	0.050 MLD STP at Kirtinagar (BRO Bridge)	7.36	130	134	7.43	7	12	33	25-10-2020
25	0.010 MLD STP at Kirtinagar (Near Temple)	6.89	130	142	7.22	8	14	43	25-10-2020
26	0.075 MLD STP at Devprayag	7.46	150	142	7.55	14	40	220	25-10-2020
27	0.150 MLD MLD STP at Devprayag	6.57	145	146	7.76	12	36	240	25-10-2020
28	1.4 MLD STP at Devprayag (Pauri Road)	6.8	155	168	7.85	8	12	130	25-10-2020
29	5 MLD STP at Bhagirathipuram, Tehri	7.11	160	172	Outlet sample not collected as plant was not in operation due				13-10-2020
30	2 MLD STP at Gyansu, Uttarkashi	7.22	160	158	7.35	10	32	350	20-10-2020
31	1 MLD STP at Gangotri, Uttarkashi	7.13	140	154	7.58	10	12	34	21-10-2020
32	3.5 MLD STP at Tapovan Rishikesh	7.28	165	160	7.9	9.6	18	46	05-10-2020
33	3 MLD STP at Swargashram Rishikesh	7.21	160	162	7.52	9.2	10	34	05-10-2020
34	26 MLD STP at Lakkarghat, Rishikesh	7.28	160	172	8.35	9.2	10	40	05-10-2020
35	5 MLD STP at Chorpani, Rishikesh	7.16	160	164	8.1	9.2	18	70	05-10-2020

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Inlet of STP			Outlet of STP				
36	7.5 MLD STP at Chandreshwar Nagar, Rishikesh	7.62	160	158	8.08	8.4	10	27	05-10-2020
37	20 MLD STP at Motharawala-I, Dehradun	7.34	165	160	7.66	9.6	10	34	05-10-2020
38	20 MLD STP at Motharawala-II, Dehradun	7.59	160	164	8.06	14	36	84	05-10-2020
39	68 MLD STP at Kargi Dehradun	7.47	165	146	7.58	9.2	9	70	05-10-2020
40	0.42 MLD STP at Vijay Colony Dehradun	7.37	165	154	7.47	16	32	280	05-10-2020
41	0.72 MLD STP Salawala Dehradun	7.29	160	170	7.7	18	44	350	05-10-2020
42	5.0 MLD STP at Indira Nagar, Dehradun	7.45	165	147	8.45	12	36	240	05-10-2020
43	1.0 MLD STP at Jakhan, Dehradun	7.36	165	160	7.77	14	38	220	05-10-2020
44	1.3 MLD STP at Landour (S), Mussoorie	7.82	160	168	8.42	14	40	220	13-10-2020
45	3.12 MLD STP at Bhatta fall, Mussoorie	7.86	165	160	7.95	12	34	170	13-10-2020
46	0.8 MLD STP at Landour (N), Mussoorie	7.33	165	154	7.76	10	32	280	13-10-2020
47	0.9 MLD STP at Kulri Bazaar, Mussoorie	7.15	170	168	7.78	14	40	430	13-10-2020
48	1.2 MLD STP at Happy Valley, Mussoorie	7.28	165	160	7.65	16	28	350	13-10-2020
49	27 MLD STP at Jagjeetpur Haridwar	7.88	160	152	7.31	8	9	84	05-10-2020
50	18 MLD STP at Jagjeetpur Haridwar	7.38	165	158	8.29	9.6	24	94	05-10-2020
51	68 MLD STP at Jagjeetpur Haridwar	7.44	165	158	7.75	9.2	10	70	05-10-2020
52	18 MLD STP at Sarai Haridwar	7.47	160	142	7.68	9.2	8	46	05-10-2020
53	14 MLD STP at Sarai Haridwar	7.51	160	136	7.77	10	16	70	05-10-2020
54	33 MLD STP at Saliyar, Roorkee, Haridwar	7.48	165	146	7.95	12	34	350	05-10-2020
55	2.0 MLD STP at Almora, Distt-Almora	—	—	—	6.43	40	92	1600	09-10-2020
56	0.45 MLD STP at Hari Nagar, Distt-Nainital	—	—	—	7.38	24	68	430	09-10-2020
57	0.80 MLD STP at Krishnapur, Distt-Nainital	—	—	—	7.17	22	60	350	09-10-2020
58	1.25 MLD STP at Bheemtal, Distt-Nainital	—	—	—	6.61	34	86	350	09-10-2020
59	10 MLD(5MLD×2) Rusi Pond at Rusi, Distt-Nainital	—	—	—	6.49	220	272	>1600	09-10-2020
60	5.0 MLD STP at Aincholi, Distt-Pithoragarh	—	—	—	7.94	48	122	1600	09-10-2020
61	1.25 MLD STP at Nirada, Distt-Pithoragarh	—	—	—	6.61	34	86	350	09-10-2020
<b>Sewage Treatment final effluent standards</b>					<b>6.5-9.0</b>	<b>30</b>	<b>&lt;50</b>	<b>&lt;1000</b>	
<b>Note: All values are in mg/l except pH and fecal coliform (MPN Per 100 ml)</b>									