

STP DATA 2011

Location	Date of Sampling	Color	Odor	pH	Suspended Solids	Dissolved Solids	Total Solids	BOD	COD
27 MLD STP Jagjeetpur, Haridwar	06.04.2011	Absent	Odorless	6.48	13	312	325	6.6	36
18 MLD STP Jagjeetpur, Haridwar	06.04.2011	Absent	Odorless	6.84	34	418	452	10.4	48
STP Oxidation Pond, Lakkarghat Rishikesh	15.04.2011	Turbid	Sewage Like	6.13	127	652	779	53	242
3 MLD STP, Swarg Ashram Rishikesh	15.04.2011	Absent	Odorless	7.94	13	345	358	6.8	28
18 MLD STP Jagjeetpur, Haridwar	13.05.2011	Absent	Odorless	6.75	32	435	467	11.4	68.4
3 MLD STP, Swarg Ashram Rishikesh	16.05.2011	Absent	Odorless	8.05	12	352	364	7.6	29
STP Oxidation Pond, Lakkarghat Rishikesh	16.05.2011	Turbid	Sewage Like	6.52	141	552	693	42	294
27 MLD STP Jagjeetpur, Haridwar	13.05.2011	Absent	Odorless	6.88	12	403	415	10.8	40
3 MLD STP, Swarg Ashram Rishikesh	15.06.2011	Absent	Sewage Like	6.7	33	396	429	14.4	68
STP Oxidation Pond, Lakkarghat Rishikesh	15.06.2011	Turbid	Sewage Like	6.86	94	566	662	24	216
27 MLD STP Jagjeetpur, Haridwar	16.06.2011	Absent	Odorless	7.05	14	424	438	9.6	48
18 MLD STP Jagjeetpur, Haridwar	16.06.2011	Absent	Odorless	6.99	23	431	454	9	45
27 MLD STP Jagjeetpur, Haridwar	14.07.2011	Absent	Odorless	7.56	13	388	401	9.3	36
18 MLD STP Jagjeetpur, Haridwar	14.07.2011	Absent	Odorless	7.62	37	391	428	11.4	42
3 MLD STP, Swarg Ashram Rishikesh	18.07.2011	Absent	Odorless	7.85	14	384	398	9	68
STP Oxidation Pond, Lakkarghat Rishikesh	18.07.2011	Turbid	Sewage Like	6.45	96	584	680	34	296

27 MLD STP Jagjeetpur, Haridwar	25.08.2011	Absent	Odorless	7.86	65	418	483	15	86
18 MLD STP Jagjeetpur, Haridwar	25.08.2011	Absent	Odorless	7.62	37	391	428	11.4	42
3 MLD STP, Swarg Ashram Rishikesh	17.08.2011	Turbid	Sewage Like	6.12	163	918	1081	116	496
STP Oxidation Pond,Lakkarghat Rishikesh	17.08.2011	Turbid	Sewage Like	7.52	123	552	675	51	306
27 MLD STP Jagjeetpur, Haridwar	23.09.2011	Absent	Odorless	7.42	22	418	440	9.2	83
18 MLD STP Jagjeetpur, Haridwar	23.09.2011	Absent	Odorless	8.12	46	522	568	12.6	96
3 MLD STP, Swarg Ashram Rishikesh	15.09.2011	Absent	Odorless	7.59	14	318	332	10.8	58
STP Oxidation Pond,Lakkarghat Rishikesh	15.09.2011	Turbid	Sewage Like	6.49	87	598	685	50	278
27 MLD STP Jagjeetpur, Haridwar	21.10.2011	Absent	Odorless	8.12	14	388	402	8.6	34
3 MLD STP, Swarg Ashram Rishikesh	14.10.2011	Absent	Odorless	8.32	11	405	416	7.3	48
STP Oxidation Pond,Lakkarghat Rishikesh	14.10.2011	Turbid	Sewage Like	7.14	84	451	535	32	199
27 MLD STP Jagjeetpur, Haridwar	9.11.2011	Absent	Odorless	7.84	13	318	331	9.3	38
18 MLD STP Jagjeetpur, Haridwar	9.11.2011	Absent	Odorless	8.12	34	412	446	15.3	62
3 MLD STP, Swarg Ashram Rishikesh	15.11.2011	Absent	Odorless	7.48	14	289	303	9	36
STP Oxidation Pond,Lakkarghat Rishikesh	15.11.2011	Turbid	Sewage Like	6.82	123	518	641	41	282
27 MLD STP Jagjeetpur, Haridwar	26.12.2011	Absent	Odorless	7.48	26	408	444	7.2	40
18 MLD STP Jagjeetpur, Haridwar	26.12.2011	Absent	Odorless	7.42	37	502	539	15.6	80
3 MLD STP, Swarg Ashram Rishikesh	19.12.2011	Absent	Odorless	7.55	15	373	390	7	32
STP Oxidation Pond,Lakkarghat Rishikesh	19.12.2011	Turbid	Sewage Like	7.48	26	618	644	33	264

STP DATA 2011

Location	Date of Sampling	Color	Odor	pH	Total Solids	BOD	COD	Total Coliform
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	20.12.2011	Absent	Odorless	7.42	12	9	38	200
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	19.12.2011	Absent	Odorless	7.89	14	8.6	34	
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	21.11.2011	Absent	Odorless	7.82	13	8.4	36	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	24.11.2011	Absent	Odorless	7.84	11	6	28	180
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	21.10.2011	Absent	Odorless	7.23	14	9.1	40	170
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	15.10.2011	Absent	Odorless	7.66	15	9.4	44	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	26.09.2011	Absent	Odorless	7.42	12	8.6	62	180
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	15.09.2011	Absent	Odorless	7.44	13	8.12	42	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	27.08.2011	Absent	Odorless	7.82	13	6.3	32	150
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	25.08.2011	Absent	Odorless	7.62	14	7.2	48	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	28.07.2011	Absent	Odorless	8.12	14	9.2	36	180
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	11.07.2011	Absent	Odorless	5.92	12	8.6	36	
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	22.06.2011	Absent	Odorless	7.12	14	9.4	36	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	26.06.2011	Absent	Odorless	7.84	12	6.8	34	200

MLD STP Gharpure Engg. Swarg Ashram Rishikesh	23.05.2011	Absent	Odorless	8.02	15	9.6	42	
27 MLD STP GECPL- UEEL Jagjeetpur,	27.05.2011	Absent	Odorless	7.85	13	10	38	180
27 MLD STP GECPL- UEEL Jagjeetpur, Haridwar	26.04.2011	Absent	Odorless	7.56	14	9.8	42	200
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	13.04.2011	Absent	Odorless	7.89	14	9.2	34	