

## STP DATA 2012

Location	Date of Sampling	Color	Odor	pH	Suspended Solids	Dissolved Solids	Total Solids	BOD	COD
18 MLD STP Jagjeetpur, Haridwar	30.11.2012	Absent	Odorless	7.84	93	510	603	28	140
27 MLD STP Jagjeetpur, Haridwar	30.11.2012	Absent	Odorless	7.67	20	382	402	10	46
STP Oxidation Pond, Lakkarghat	23.11.2012	Turbid	Unpleasant	8.24	138	733	871	56	260
3,MLD STP Swarg Ashram Rishikesh	23.11.2012	Absent	Odorless	7.9	26	286	312	12	46
STP Oxidation Pond Lakkarghat Rishikesh	31.10.2012	Turbid	Unpleasant	7.41	143	764	907	72	270
3,MLD STP Swarg Ashram Rishikesh	31.10.2012	Absent	Odorless	7.67	19	297	316	10	44
18 MLD STP Jagjeetpur, Haridwar	30.10.2012	Absent	Odorless	7.59	112	543	655	28	110
27 MLD STP Jagjeetpur, Haridwar	30.10.2012	Absent	Odorless	7.44	21	357	378	13	48
18 MLD STP Jagjeetpur, Haridwar	28.09.2012	Absent	Odorless	7.66	84	467	551	24	78
27 MLD STP Jagjeetpur, Haridwar	28.09.2012	Absent	Odorless	7.62	19	334	353	11	42
3,MLD STP Swarg Ashram Rishikesh	24.09.2012	Absent	Odorless	7.58	23	324	351	16	54
STP Oxidation Pond, Lakkarghat	24.09.2012	Turbid	Unpleasant	7.19	117	646	763	54	238
STP Oxidation Pond, Lakkarghat	23.08.2012	Turbid	Unpleasant	7.26	126	673	799	52	260
3,MLD STP Swarg Ashram Rishikesh	23.08.2012	Absent	Odorless	7.46	23	381	404	14	48
27 MLD STP Jagjeetpur, Haridwar	25.08.2012	Absent	Odorless	7.67	24	375	399	12	46
18 MLD STP Jagjeetpur, Haridwar	25.08.2012	Absent	Odorless	7.5	73	488	561	20	84
27 MLD STP Jagjeetpur, Haridwar	07.07.2012	Absent	Odorless	7.42	19	354	373	15	42
18 MLD STP Jagjeetpur, Haridwar	07.07.2012	Absent	Odorless	7.41	66	462	528	24	98
3, MLD STP Swarg Ashram Rishikesh	04.07.2012	Absent	Odorless	7.22	22	350	372	13	38
STP Oxidation Pond, Lakkarghat	04.07.2012	Turbid	Unpleasant	7.48	102	615	717	44	278
STP Oxidation Pond, Lakkarghat	19.06.2012	Turbid	Unpleasant	8.16	87	611	698	54	242

3, MLD STP Swarg Ashram Rishikesh	19.06.2012	Absent	Odorless	7.42	18	352	370	16	52
18 MLD STP Jagjeetpur, Haridwar	19.06.2012	Absent	Odorless	7.9	57	472	529	27	109
27 MLD STP Jagjeetpur, Haridwar	19.06.2012	Absent	Odorless	7.98	35	453	488	17	68
27 MLD STP Jagjeetpur, Haridwar	15.05.2012	Absent	Odorless	7.64	14	442	456	8.1	36
18 MLD STP Jagjeetpur, Haridwar	15.05.2012	Absent	Odorless	7.88	33	458	491	12.6	64
3, MLD STP Swarg Ashram Rishikesh	4.05.2012	Absent	Odorless	7.3	22	462	484	19	72
STP Oxidation Pond,Lakkarghat	4.05.2012	Turbid	Unpleasant	7.55	132	634	766	35	280
STP Oxidation Pond,Lakkarghat	10.04.2012	Turbid	Unpleasant	7.97	82	615	697	58	268
3, MLD STP Swarg Ashram Rishikesh	11.04.2012	Absent	Odorless	7.46	24	459	483	15.5	86
18 MLD STP Jagjeetpur, Haridwar	10.04.2012	Absent	Odorless	7.36	24	450	474	11	44
27 MLD STP Jagjeetpur, Haridwar	10.04.2012	Absent	Odorless	7.48	13	439	452	7.8	39
STP Oxidation Pond,Lakkarghat	31.03.2012	Turbid	Sewage Like	6.42	121	618	739	47	235
3 MLD STP, Swarg Ashram Rishikesh	31.03.2012	Absent	Odorless	7.42	13	302	315	10	36
18 MLD STP Jagjeetpur, Haridwar	20.03.2012	Absent	Odorless	7.42	38	318	356	13.8	56
27 MLD STP Jagjeetpur, Haridwar	20.03.2012	Absent	Odorless	7.12	22	308	330	11	42
27 MLD STP Jagjeetpur, Haridwar	24.02.2012	Absent	Odorless	7.82	18	312	330	12.9	42
18 MLD STP Jagjeetpur, Haridwar	24.02.2012	Absent	Odorless	8.12	46	396	442	14	68
3 MLD STP, Swarg Ashram Rishikesh	24.02.2012	Absent	Odorless	6.82	22	318	340	9.9	42
STP Oxidation Pond,Lakkarghat	24.02.2012	Turbid	Sewage Like	7.42	125	618	743	44	308
27 MLD STP Jagjeetpur, Haridwar	07.01.2012	Absent	Odorless	7.42	22	388	410	10	42
18 MLD STP Jagjeetpur, Haridwar	07.01.2012	Absent	Odorless	7.81	57	518	575	12.2	52
3 MLD STP, Swarg Ashram Rishikesh	25.01.2012	Absent	Odorless	7.42	13	306	319	7.4	32
STP Oxidation Pond,Lakkarghat	25.01.2012	Turbid	Sewage Like	6.81	143	618	761	43	301
18 MLD STP Jagjeetpur, Haridwar	30.11.2012	Absent	Odorless	7.84	93	510	603	28	140
27 MLD STP Jagjeetpur, Haridwar	30.11.2012	Absent	Odorless	7.67	20	382	402	10	46

STP Oxidation Pond,Lakkarghat	23.11.2012	Turbid	Unpleasant	8.24	138	733	871	56	260
3 MLD STP, Swarg Ashram Rishikesh	23.11.2012	Absent	Odorless	7.9	26	286	312	12	46

## STP DATA 2012

Location	Date of Sampling	Color	Odor	pH	Suspended Solids	BOD	COD	Total Coliform
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	20.07.2012	Absent	Odorless	7.22	15	13.2	36	180
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	18.07.2012	Absent	Odorless	7.16	14	9.6	42	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	25.06.2012	Absent	Odorless	6.84	22	12.3	48	220
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	20.06.2012	Absent	Odorless	7.24	18	10.2	46	
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	17.05.2012	Absent	Odorless	7.11	14	8.6	34	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	23.05.2012	Absent	Odorless	7.21	15	9.6	36	180
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	23.04.2012	Absent	Odorless	7.32	13	10	42	170
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	21.04.2012	Absent	Odorless	7.32	15	9.4		
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	18.03.2012	Absent	Odorless	7.41	14	9.2	40	180
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	17.03.2012	Absent	Odorless	6.98	15	8.8	36	
27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	18.02.2012	Absent	Odorless	7.22	13	9.6	42	200
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	18.02.2012	Absent	Odorless	7.23	14	9.4	32	

27 MLD STP GECPL-UEEL Jagjeetpur, Haridwar	20.01.2012	Absent	Odorless	7.38	14	9.4	40	180
MLD STP Gharpure Engg. Swarg Ashram Rishikesh	20.01.2012	Absent	Odorless	7.42	12	9.6	36	