

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Sampling Point							
		Inlet of STP			Outlet of STP			Fecal Coliform	Sampling Date
		pH	BOD	TSS	pH	BOD	TSS		
1	0.26 MLD STP at Badrinath (Banni Gaon), Distt-Chamoli	Sample not taken due to Seasonal Closure							
2	0.010 MLD STP at Badrinath (Near Temple), Distt-Chamoli								
3	1.0 MLD STP at Badrinath (Near suspension Bridge), Distt-Chamoli								
4	1.080 MLD STP at Joshimath (Pokhri), Distt-Chamoli	6.76	125	122	7.16	8.4	9	58	29-01-2021
5	0.760 MLD STP at Gopeshwar (Chamoli Ghat), Distt-Chamoli	6.8	120	114	7.5	8.8	12	63	29-01-2021
6	0.050 MLD STP at Gopeshwar (Near old Suspension Bridge), Chamoli	6.61	110	118	7.16	9.6	10	84	29-01-2021
7	1.190 MLD STP at Gopeshwar (Vivekanand Colony), Distt-Chamoli	6.73	120	116	7.18	9.2	10	47	29-01-2021
8	1.120 MLD STP at Gopeshwar (Deen Dayal Upadhyay Park), Distt-Chamoli	6.92	110	120	7.12	8.4	9.6	40	29-01-2021
9	1.25 MLD STP at Gopeshwar (Pokhari Band), Distt-Chamoli	6.75	120	110	7.84	8	9	38	29-01-2021
10	0.050 MLD STP at Nandprayag (Sangam Road), Distt-Chamoli	6.74	110	120	7.48	8	8	40	29-01-2021
11	0.100 MLD STP at Nandprayag (Forest office), Distt-Chamoli	6.43	130	128	7.6	9.6	9	58	29-01-2021
12	0.050 MLD STP at Karanprayag (Police chowki), Distt-Chamoli	7.03	115	116	7.4	9.8	9	34	28-01-2021
13	0.100 MLD STP at Karanprayag (Purana pull), Distt-Chamoli	6.72	130	112	7.8	8	10	46	28-01-2021
14	0.100 MLD STP at Karanprayag (Ward no. 1&3), Distt-Chamoli	6.82	120	108	7.37	8	10	84	28-01-2021
15	0.050 MLD STP at Karanprayag (Subhash Nagar), Distt-Chamoli	6.94	125	132	7.3	8.8	8	79	28-01-2021
16	0.050 MLD STP at Karanprayag (Naya Pull), Distt-Chamoli	6.89	110	126	7.4	9.2	9	48	28-01-2021
17	0.075 MLD MLD STP at Rudraprayag (Near Anoop Negi School)	6.95	100	84	7.17	7.6	9	17	30-01-2021
18	0.100 MLD STP at Rudraprayag (Near Rudra Complex)	6.22	110	130	7.18	9.6	12	46	30-01-2021
19	0.075 MLD STP at Rudraprayag (Near Bus Stand)	6.7	115	132	7.2	10	10	58	30-01-2021
20	0.100 MLD STP at Rudraprayag (Near SBI Maszid)	6.68	120	116	7.24	9.6	16	63	30-01-2021
21	0.125 MLD STP at Rudraprayag (Near Steel Bridge & Syndicate Bank)	Plant was not in operation due to Electrical Fault							30-01-2021
22	0.050 MLD STP at Beleni Road, Near Steel Bridge, Rudraprayag	6.74	140	100	7.25	10	10	40	30-01-2021
23	3.5 MLD STP at Srinagar (Nursary Road)	6.8	165	152	7.44	18	26	120	30-01-2021
24	1.000 MLD STP at Srinagar (Near ITI)	6.85	120	128	7.75	9.6	9	14	30-01-2021
25	75 KLD STP Near Junior High School, Srikot, Srinagar	6.78	100	112	7.08	9.6	12	32	30-01-2021
26	50 KLD STP Near Tauliya Nala, Srikot, Srinagar	6.97	110	108	7.64	10	14	48	30-01-2021
27	0.050 MLD STP at Kirtinagar (BRO Bridge)	6.91	115	110	7.5	8	9	34	30-01-2021
28	0.010 MLD STP at Kirtinagar (Near Temple)	6.68	110	130	7.13	9.2	12	58	30-01-2021
29	0.075 MLD STP at Devprayag	6.76	145	134	7.05	16	22	40	30-01-2021
30	0.150 MLD MLD STP at Devprayag	6.94	140	126	7.03	14	18	50	30-01-2021
31	1.4 MLD STP at Devprayag (Pauri Road)	6.35	160	164	7.16	8.4	8	58	30-01-2021
32	5 MLD STP at Bhagirathipuram, Tehri	6.94	155	150	7	9.6	12	94	13-01-2021
33	2 MLD STP at Gyansu, Uttarkashi	6.94	160	156	7.71	9.2	12	110	07-1-2021
34	1 MLD STP at Gangotri, Uttarkashi	Sample not taken due to Seasonal Closure							

S.No.	Name of the Sewage Treatment Plant (With Capacity)	Inlet of STP			Outlet of STP				
35	3.5 MLD STP at Tapovan Rishikesh	6.84	160	170	7.3	7.6	10	46	12-01-2021
36	3 MLD STP at Swargashram Rishikesh	6.91	140	152	7.12	8	8	38	12-01-2021
37	26 MLD STP at Lakkarghat, Rishikesh	6.79	155	142	7.3	8	9	48	12-01-2021
38	5 MLD STP at Chorpani, Rishikesh	7.3	170	166	7.25	9.2	10	110	12-01-2021
39	7.5 MLD STP at Chandreshwar Nagar, Rishikesh	6.86	140	155	7.2	8.4	9	47	12-01-2021
40	20 MLD STP at Motharawala-I, Dehradun	6.95	175	170	7.34	9.6	9	63	12-01-2021
41	20 MLD STP at Motharawala-II, Dehradun	7.89	170	182	7.48	8	10	58	12-01-2021
42	68 MLD STP at Kargi Dehradun	6.96	175	150	7.3	8.4	9	70	12-01-2021
43	0.42 MLD STP at Vijay Colony Dehradun	6.76	155	118	7.32	9.6	14	94	12-01-2021
44	0.72 MLD STP Salawala Dehradun	6.87	160	130	7.5	9.2	12	84	12-01-2021
45	5.0 MLD STP at Indira Nagar, Dehradun	6.81	160	146	7.28	10	16	120	12-01-2021
46	1.0 MLD STP at Jakhan, Dehradun	7.21	110	125	7.38	10	14	94	12-01-2021
47	27 MLD STP at Jagjeetpur Haridwar	6.95	165	160	7.25	9.6	9	70	22-01-2021
48	18 MLD STP at Jagjeetpur Haridwar	7.16	160	138	7.2	9.6	12	70	22-01-2021
49	68 MLD STP at Jagjeetpur Haridwar	6.79	165	160	7.05	8.8	10	63	22-01-2021
50	18 MLD STP at Sarai Haridwar	7.86	170	132	7.15	8.4	9	38	22-01-2021
51	14 MLD STP at Sarai Haridwar	7.09	160	158	7.11	9.2	10	48	22-01-2021
52	33 MLD STP at Saliyar, Roorkee, Haridwar	6.47	160	127	7.32	10	14	110	22-01-2021
53	1.3 MLD STP at Landour (S), Mussoorie	7.2	140	138	7.55	8.8	12	110	04-01-2021
54	3.12 MLD STP at Bhatta fall, Mussoorie	7.33	150	164	7.46	9.2	10	94	04-01-2021
55	0.8 MLD STP at Landour (N), Mussoorie	6.31	130	122	6.79	10	14	120	04-01-2021
56	1.2 MLD STP at Happy Valley, Mussoorie	7.49	155	145	7.63	9.2	10	140	04-01-2021
57	0.9 MLD STP at Kulri Bazaar, Mussoorie	7.49	140	144	7.3	9.6	9	170	04-01-2021
58	2.0 MLD STP at Almora, Distt-Almora	—	—	—	7.22	26	54	540	16-01-2021
59	0.45 MLD STP at Hari Nagar, Distt-Nainital	—	—	—	7.76	18	36	350	16-01-2021
60	0.80 MLD STP at Krishnapur, Distt-Nainital	—	—	—	7.35	14	44	220	16-01-2021
61	1.25 MLD STP at Bheemtal, Distt-Nainital	—	—	—	6.94	29	72	540	16-01-2021
62	5.0 MLD STP at Aincholi, Distt-Pithoragarh	—	—	—	7.95	16	48	150	16-01-2021
63	1.25 MLD STP at Nirada, Distt-Pithoragarh	—	—	—	7.28	30	66	920	16-01-2021
Sewage Treatment final effluent standards					6.5-9.0	<30	<50	<1000	
Note: All values are in mg/l except pH and fecal coliform (MPN Per 100 ml)									